



Replacement Sheet




FIG. 4




Fig. 17




Fig. 18

Replacement Sheet





Fig. 19

Replacement Sheet

Terminal Status
Modules
Version Info
Configuration
Metrics
Self Tests
Status Log
Service Calls
Service Docs

Status & Tests
Service Calls
Status Log
Version Info
Configuration
Metrics
Service Docs
Firmware Downloads

Advanced Function Dispenser (1): Normal Operation



View 1 of 1

Module Tests and Commands:

- Reset Test
- Self Test
- Sensor State Test
- Firmware Download
- Lead Through Test
- SetAFD Communication
- Get Cassette Information
- Calibrate
- Generate Engineering Data (DAQ) Test
- Diverter Test
- Exit Shutter Test
- Last Assert Test
- Motor Test
- Push Plate Test
- Transport Test
- Tray Test

Run Test

Component	Status
<input checked="" type="checkbox"/> USB Result	OK
<input checked="" type="checkbox"/> Security Result	OK
<input checked="" type="checkbox"/> Module	All module functions available
<input checked="" type="checkbox"/> CCA board	0X000
<input checked="" type="checkbox"/> Status	OK
<input checked="" type="checkbox"/> Dispense Transaction	OK
<input checked="" type="checkbox"/> Stacker Sensor Condition	OK
<input checked="" type="checkbox"/> Dispense Transaction	NV

% Recovery Action {Cassette 4: 0x0002}

Click on bitfield values:

Fig. 20




Fig. 21

2540




Fig. 22

Module Tests and Commands	
Reset Test	^
Self Test	
Sensor State Test	
Firmware Download	V
Lead through Test	
Set AFD Communication	
Get Cassette Information	
Calibrate	
Generate Engineering Data (DAQ) Test	
Diverter Test	
Exit Shutter Test	
Last Assert Test	
Motor Test	
Push Plate Test	
Transport Test	
Tray Test	

Fig. 23

Diebold Diagnostics

Terminal Status

Modules

Version Info

Configuration

Metrics

Self Tests

Status Log

Service Calls

Service Docs

Status & Tests

Service Calls

Status Log

Version Info

Configuration

Metrics

Service Docs

Address: D:\Techpos800KSTM200001\001\1030001\html\S5173002

Back

Forward

Home

Go

4.1.2 Replacement

To replace the fascia plate, reverse the removal procedure.
Grease the gate with Diebold lubricant (PN 16-003082-000A) before

Figure 4-1 Removing the Lead-through Indicator and Exit





Fig. 24






Fig. 30




Fig. 31




Fig. 32




Fig. 33